

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

December 22, 2009

STRATFORD HOMES LTD. STEVE SCHOENFUSS PO BOX 37 STRATFORD WI 54484

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: STRATFORD HOMES LTD.

Product Name: KITCHEN SINK - DISHWASHER OPTION

Model Number(s): SH-2-05-K7 Product File No: 20090425

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2015.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on March 22, 2015 under product file number 20050087.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050087.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 09042501.DOC